



425 Hanley Industrial Court, St. Louis, MO 63144
 Phone: (314) 644-4300, Fax: (314) 644-5332
 www.indeeco.com

INSTALLATION INSTRUCTIONS
For INDEECO of the commercial ceiling heater
«CCI Series» 6 to 8 kW

THE INSTALLATION MUST BE EXECUTED
 BY A QUALIFIED TECHNICIAN



RECESS MOUNTING

- 1- Heater must be used with recess box as shown.
- 2- Never install warm air outlet of heater less than 250 mm (10 in.) from adjacent wall.
- 3- Provide an opening as shown 108 mm (4.25 in.) deep minimum.
- 4- Remove the appropriate knockout from the recess box for the electrical supply.
- 5- Attach firmly the recess box using provided screws.
- 6- Install the heater to the recess box and be sure that the heater is attach firmly with four (4) provided screws.
- 7- Connect the supply leads to the heater leads or terminal block according to local and national codes. The control (thermostat or relay) of the heater must be connected to the T1-T2 position on the terminal block and must never cut the power so that the device eliminating the residual heat (fan delay) remains energized.
- 8- Make sure the fan rotates freely and that there is no foreign object in the heater.
- 9- Install the front cover using the provided screws.
 IMPORTANT: Make sure that the part of the front cover without louvers is in front of the supply terminal box.
- 10-To test the heater temporarily, set thermostat at maximum temperature.

SURFACE MOUNTING

- 1- The surface box must be used with recess box as shown.
- 2- Never install warm air outlet of heater less than 250 mm (10 in.) from adjacent wall.
- 3- Locate the power supply leads behind the planned location of the heater (surface box).

SURFACE MOUNTING (continuation)

- 4- Mount the surface box securely to the ceiling with provided screws.
- 5- Install both (top and bottom) of the grill support before reinstalling the grill on the surface box.
- 6- Follow instructions 4 to 10 as above for recess mounting.

DROP CEILING MOUNTING

- 1- Install the T-BAR ceiling adapter on the ceiling with wires or chains.
- 2- Mount the recess box on the T-BAR with six (6) provided screws.
- 3- Follow instructions 4 to 9 as above for recess mounting.

IMPORTANT
 Connect the control (thermostat or relay) to the T1-T2 position on the terminal block.

IMPORTANT
 This unit could weight up to: 52 lbs (24Kg)
 Install the T-BAR ceiling adapter solidly to the ceiling trust.

IMPORTANT
 Do not obstruct front of heater for at least 1220 mm (48 in.).
 Never install warm air outlet of the heater less that 250 mm (10 in.) from adjacent wall.

OPTIONS

See installation pamphlet provided with option to install relay and relay with transformer kits on site.

ATTENTION

- Basic precautions should always be followed to reduce the risk of fire, electric shock, and injury to persons.
- Read all instructions before using this heater.
 - Do not use outdoors.
 - Do not insert or allow foreign objects to enter any ventilation or exhaust opening as this may cause an electric shock or fire, or damage the heater.
 - Do not block air intakes or exhaust in any manner.
 - Heater contains arcing and sparking parts. Do not use it in areas where gasoline, paint, or flammable liquids are used or stored.
 - Use this heater only as described in this manual. Any other use not recommended by the manufacturer may cause fire, electric shock, or injury to persons.

MAINTENANCE

Once a year, remove the grill and use a vacuum cleaner to remove the dust accumulation inside the heater. Cleaning should be done while the heater is disconnected from the supply circuit.

A qualified technician should perform any other servicing.

KEEP THIS INSTRUCTION PAMPHLET FOR THE USER INS167-200204-02

